



2007 annual water quality report



**Agua Fria
District**

PWS ID: 04-07-695



Dear Arizona American Water Customer,

You are our top priority. And delivering reliable, high-quality water to you all day, every day is our mission. We deliver — at about a penny per gallon.

Each year, Arizona American Water publishes reports on the quality of your drinking water. We are pleased to report that investment in our water treatment plants and equipment, as well as the expertise and dedication of our employees, allows us to deliver drinking water that meets state and federal drinking water requirements. In addition to ensuring we are following current standards, we work closely with federal agencies to anticipate future water quality treatment requirements and regulations.

Your community is our community. We work with local and state governments to make sure your water service needs are being met. From upgrading existing systems to developing new ones, from pitching in at local events to sponsoring school programs, we are your neighbors and take your water quality personally.

We encourage you to review this report either in this printed form or on our website at www.amwater.com. If you ever have any questions, please reach out to our customer service representatives at (800) 383-0834. After all, you are our first priority.

Thank you for being an Arizona American Water customer.

Paul Townsley
President
Arizona American Water

What is a Water Quality Report?

To comply with state and U.S. Environmental Protection Agency (EPA) regulations, Arizona American Water issues an annual water quality report which describes the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and your awareness of the need to protect your drinking water sources. This report includes details about where your water comes from and what it contains. This data presented in this report is a combination of data from our nationally recognized water quality lab and commercial laboratories all certified in drinking water testing by the State of Arizona Department of Health Services. If you have any questions about this report or your drinking water, please call our Arizona Customer Service Center at 1 (888) 237-1333.

Share this Report

Landlords, businesses, schools, hospitals and other groups are encouraged to share this important water quality information with water users at their location who are not billed customers of Arizona American Water Company and therefore do not receive this report directly.

Our Customer Charter

We Are....

- dedicated to service excellence
 - focused on personalized solutions
 - committed to our customers' health and welfare
- therefore...**

We Will...

- partner with our customers
- treat them with dignity and respect
- enhance their quality of life
- earn their loyalty
- exceed their expectations

Where Does My Water Come From?

All of the water provided by Arizona American Water comes from groundwater pumped from the West Salt River Valley (WSRV) Sub-Basin. The WSRV Sub-Basin is a broad, gently sloping alluvial plain that is bounded on the north by the Hieroglyphic Mountains and Hedgpeth Hills and on the west by the White Tank Mountains. Along the eastern boundary of the WSRV Sub-Basin are the Union Hills, Phoenix Mountains, and Papago Buttes. South Mountains, Estrella Mountains, and Buckeye Hills define the southern limits of the WSRV Sub-Basin.

Depth to groundwater in the WSRV Sub-Basin varies from 150 to over 500 feet. Sources of groundwater include natural recharge from flood flows in streams and along mountain fronts, and incidental recharge from agricultural and urban irrigation, canals, effluent, and artificial lakes.

Notice of Source Water Assessment Agua Fria

In 2004 the Arizona Department of Environmental Quality completed a source water assessment for 15 wells used by Arizona American Water Company-Agua Fria. The Assessment reviewed the adjacent land uses that may pose a potential risk to the sources. These risks include, but are not limited to, gas stations, landfills, dry cleaners, agriculture fields, waste water treatment plants, and mining activities. Once ADEQ identified the adjacent land uses, they were ranked as to their potential to affect the water sources. The results of the assessment were that six wells had no adjacent land uses that posed a risk, ten wells had one adjacent land use that posed a low risk, and two wells had one adjacent land use that posed a high risk.

The complete Assessment is available for inspection at the Arizona Department of Environmental Quality, 1110 W. Washington, Phoenix, Arizona 85007, between the hours of 8:00 a.m. and 5:00 p.m. Electronic copies are available from ADEQ at dml@azdeq.gov. For more information, please contact ADEQ's Source Water Assessment and Protection Unit at 602-771-4644 or visit their website www.azdeq.gov/environ/water/dw/swap.html.

What we do to protect groundwater:

We protect the sources by ensuring proper well construction and system operations and management.

What you can do to protect groundwater:

Residents can help by taking hazardous household chemicals to hazardous material collection days, and limiting pesticide & fertilizer use. For information on household hazardous material collection days in your area, please contact the City of Surprise at (623) 594-5858.

Home Water Treatment Units

If you install a home treatment system such as a water softener or reverse osmosis system to improve taste or odor, remember to follow the manufacturer's instructions on operation and maintenance. Failure to perform maintenance can result in poor water quality. We recommend contacting the manufacturer of your treatment system for maintenance instructions or assistance. Additional information about home treatment systems is available from the Arizona Water Quality Association at 480-947-9850 or by writing to 6819 E. Diamond St., Scottsdale, AZ 85257.

Water Conservation Tips

Conservation measures you can use inside your home include:

- Fix leaking faucets, pipes, toilets, etc.
- Replace old fixtures; install water-saving devices in faucets, toilets and appliances.
- Wash only full loads of laundry.
- Do not use the toilet for trash disposal.
- Take shorter showers.
- Do not let the water run while shaving or brushing teeth.
- Soak dishes before washing.
- Run the dishwasher only when full.

You can conserve outdoors as well:

- Water the lawn and garden in the early morning or evening.
- Use mulch around plants and shrubs.
- Repair leaks in faucets and hoses.
- Use water-saving nozzles.
- Use water from a bucket to wash your car, and save the hose for rinsing.

What is In My Water?

This data presented in this report is a combination of analysis results from our nationally recognized water quality lab and commercial laboratories, all certified in drinking water testing by the State of Arizona Department of Health Services. For your information, we have compiled a list in the table below showing what substances were detected in our drinking water during 2007 or the last sampling period. If you have any questions about this report or your drinking water, please call our Arizona Customer Service Center at (800) 383-0834.

Water Quality Results

| Regulated Substances Measured on the Water Leaving the Treatment Facility | | | | | | | | |
|---|--------------|-------------------------|---------------------|---|---------------------|--------------------------------------|---|--|
| Substance (units) | Year Sampled | MCLG | MCL | Highest Amount Detected | Range of Detections | Compliance Achieved | Typical Source | |
| Arsenic (ppb) | 2007 | NA | 10 | 35 ¹ | 5 – 35 | YES [*] | Erosion of natural deposits | |
| Barium (ppb) | 2006 | 2000 | 2000 | 39 | 4 – 39 | YES | Erosion of natural deposits | |
| Chromium (ppb) | 2005 | 100 | 100 | 72 | 19 – 72 | YES | Erosion of natural deposits | |
| Fluoride (ppm) | 2007 | 4 | 4 | 1.7 | 0.8 – 1.7 | YES | Erosion of natural deposits | |
| Nitrate ² (ppm) | 2007 | 10 | 10 | 8.2 | 0.9 – 8.2 | YES | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits | |
| Alpha Emitters (pCi/L) | 2002 | 0 | 15 | 4.9 | 1.6 – 4.9 | YES | Erosion of natural deposits | |
| Other Compounds Measured in the Distribution System | | | | | | | | |
| Substance (units) | Year Sampled | MCLG/ MRDL | MCL | Average Amount Detected | Range of Detections | Compliance Achieved | Typical Source | |
| TTHMs (ppb) | 2007 | NA ³ | 100 | 2.5 | ND – 10.9 | YES | By-product of drinking water disinfection | |
| HAA5s (ppb) | 2007 | NA ³ | 60 | 0.3 | ND – 1.5 | YES | By-product of drinking water disinfection | |
| Chlorine residual (ppm) | 2007 | 4 | 4 | 1.0 | ND – 2.2 | YES | Water additive used to control microbes | |
| Tap Water Samples: Lead and Copper Results | | | | | | | | |
| Substance (units) | Year Sampled | MCLG | Action Level | 90th Percentile | Number of Samples | Number of Samples Above Action Level | Compliance Achieved | Typical Source |
| Copper (ppm) | 2007 | 1.3 | 1.3 | 0.1 | 35 | 0 | YES | Corrosion of household plumbing systems; erosion of natural deposits |
| Unregulated Substances Measured on the Water Leaving the Treatment Facility | | | | | | | | |
| Substance (units) | Year Sampled | Highest Amount Detected | Range of Detections | Typical Source | | | | |
| Sodium (ppm) | 2006 | 100 | 46 – 100 | Natural erosion | | | | |
| Sulfate (ppm) | 2005 | 66 | 17 – 66 | Natural erosion | | | | |
| Hardness (grains/gallon) | 2005 | 7 | 3 – 7 | Natural calcium/magnesium content | | | | |
| pH (standard units) | 2005 | 8.3 | 7.5 – 8.3 | pH is a measure of acid/base properties | | | | |
| Iron (ppm) | 2005 | <0.1 | <0.1 (ND) | Natural content | | | | |

¹ Arsenic – **A Notice to Our Customers in Verrado:**
In 2006, Arizona American Water began construction of an arsenic removal facility to serve our customers in Verrado. The facility was necessary to remove the naturally-occurring arsenic in the groundwater in the Verrado area and to comply with the EPA's new arsenic MCL requirement of 10 ppb. Our goal was to have the arsenic removal facility completed by January 2007. Due to delays in construction and testing, the facility was not completed and operational until April 2007. Compliance with the arsenic MCL requirement is based on four quarterly samples, and because of the delay in the facilities operation, the 2007 annual average for arsenic in Verrado was 13.7 ppb. We want to assure you that the arsenic removal facility has been operational since April 2007, and the water you've received since then has been less than the EPA's arsenic MCL requirement of 10 ppb. If you have any questions regarding this information, please contact our Arizona Customer Service Center at (888) 237-1333. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

² Nitrate – Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

³ TTHM/HAA5 – Although there is no collective MCLG for this contaminant group, there are individual MCLGs for some of the individual contaminants:
Trihalomethanes: bromodichloromethane (zero); bromoform (zero); dibromochloromethane (0.06 mg/L). Chloroform is regulated with this group but has no MCLG.
Haloacetic acids: dichloroacetic acid (zero); trichloroacetic acid (0.3 mg/L). Monochloroacetic acid, bromoacetic acid, and dibromoacetic acid are regulated with this group but have no MCLGs.

How to Read This Table

Arizona American Water conducts extensive monitoring to ensure that your water meets all water quality standards. The results of our monitoring are reported in the adjacent tables. For help with interpreting this table, see the "Table Definitions" section.

Starting with a **Substance**, read across. **Year Sampled** is usually in 2007 or prior. **MCLG** is the goal level for that substance (this may be lower than what is allowed). **MCL** shows the highest level of substance (contaminant) allowed. **Highest Amount Detected** represents the highest result that was found. **Range of Detections** tells the highest and lowest amounts found. A **Yes** under **Compliance Achieved** means the amount of the substance is below government requirements. **Typical Source** tells where the substance usually originates.

Unregulated substances are measured, but maximum contaminant levels have not been established by the government.

Definitions of Terms Used in This Report

- **gpg or grains/gallon:** Used to describe the dissolved hardness minerals contained in water and is a unit of weight that equals 1/7000 of a pound.
- **MCL (Maximum Contaminant Level):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **MCLG (Maximum Contaminant Level Goal):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MRDL (Maximum Residual Disinfectant Level):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **MRDLG (Maximum Residual Disinfectant Level Goal):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **TT (Treatment Technique):** A required process intended to reduce the level of a contaminant in drinking water.
- **AL (Action Level):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- **ND:** None detected
- **pCi/L (Picocuries per liter):** Measurement of the natural rate of disintegration.
- **ppb – Parts per billion:** One part substance per billion parts water (or micrograms per liter).
- **ppm – Parts per million:** One part substance per million parts water (or milligrams per liter).
- **TTHM – Total Trihalomethanes:** Consist of Chloroform, Bromoform, Bromodichloromethane, Dibromochloromethane.
- **HAA5 – Haloacetic Acids:** Consist of Monochloroacetic Acid, Dichloroacetic Acid, Trichloroacetic Acid, Bromoacetic Acid, Dibromoacetic Acid.

Substances Expected to be in Drinking Water

To ensure that tap water is safe to drink, U.S. EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it can acquire naturally occurring minerals and, in some cases, radioactive material, and substances resulting from the presence of animals or from human activity.

Substances that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife.

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides, which may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and may also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities.

For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at 1-800-426-4791.

White Tanks Regional Water Treatment Plant

Arizona American Water commenced construction in November 2007 on the White Tanks Regional Water Treatment Plant, one of the largest jointly owned public-private water treatment plants in the state. The facility will use Colorado River water to reduce reliance upon scarce groundwater in the West Valley of Maricopa County. The plant is to be fully operational by 2010 and will ensure that we can provide you with a reliable and renewable water source.



19820 N. 7th Street, Suite 201
Phoenix, AZ 85024

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien. 1-(800) 383-0834

For more information about this report, or for any questions relating to your drinking water, please call our customer service center at 1-(800) 383-0834.

Special Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead

Arizona American Water Company monitored the water for lead and copper in 2007 at 35 residences throughout the community and met the federal lead and copper standards. The 35 houses sampled were representative of the types of houses throughout the system. If your house was sampled you would have received the analysis results. If you weren't part of the representative sampling and are concerned about elevated lead levels in your home's water, you may wish to flush your tap for 30 seconds to 2 minutes before using the water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791).

How Did We Do?

Our water quality report is intended to provide you with valuable information on your water. Call us TOLL FREE at 1-866-464-0228.

By completing a short phone survey (6 yes/no questions), you will help us improve the value of the information we provide to you each year.